

OFFICE OF VILLAGE PANCHAYATH, TEGURU.

E-mail: Id:

Telephone No. 08262-224210

OVVAL SEAL OF : OFFICE OF VILLAGE
PANCHAYATH, TEGURU, CHIKMAGALURU
TALUK, No. Po.No.V.P. The 48/2023-24
Dated: 02.05.2023

Date: 02.05.2023.

APPENDIX-XIII
:: PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE::

It is certified that an inspection team headed by Smt. Smitha P.J., Panchayath Development Officer, Tegur from Rural Development and Panchayath Raj Department inspected the Minority Morarji Desai Residential School, Tegur, Rampura (post), Chikmagaluru Taluk & Dist. on D: 02.05.2023 and found that the Minority Morarji Desai Residential School, Tegur, Rampura (post), Chikmagaluru Taluk & Dist. has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.T. Govt. The above is valid for a period of Date: 01.05.2024.

To,
The Principal,
Minority Morarji Desai
Residential School,
Tegur, Rampura (post)
Chikmagaluru (Taluk & Dist.)-577133

sd/- in English (SEAL OF)
Panchayath Development Officer,
Tegur Grama Panchayath,
CHIKMAGALURU TALUK

:: CERTIFICATE::

This is to certify that the undersigned has translated the above Certificate / Text from Kannada to English language, which is literal, true & correct.

CHIKAMAGALURU
Date: 02.05.2023

VERIFIED & FOUND AS CORRECT"
DISTRICT OFFICER
Minorities Welfare Dept
Chikkamagalur.

Sans
Principal
Minority Morarji Desai
Residential School
Tegur, Chikkamagaluru



Translation
Before me
V. K. RAGHU
V. K. RAGHU, B.A., LL.B.
ADVOCATE AND NOTARY
CHIKMAGALUR-577101
Mob: 9448004762



RURAL DRINKING WATER & SANITATION DIVISION

District water testing laboratory, Zilla panchayath office premises, Kadur road Chikmagalur.

TEST REPORT

Taluk: Chikmagalur Gram panchayath: Theguru Village: Theguru Habitation: Theguru Location: A.P.J Abdul kalam residential school Name: Vijaya Contact number: 8310683171	Report date: 04.03.2023
	Report Number :
	Reference : Sample receipt Form
	Sample receipt date: 03.03.2023
	Sample code:
	Date of Sample collection: 03.03.2023
	Analysis start date: 04.03.2023
	Analysis completion date: 04.03.2023
Sample collection protocol : APHA Method	
Sample Particulars: Borewell	Sample quantity: 1litre

Sl.No	Test	Results	Acceptable Limit IS 10500:2012 RA:2018	Permissible Limit IS 10500 :2012RA:2018	Protocol
Description:					
1.	pH Value@25°C	6.79	6.5-8.5	No relaxation	IS3025(Part-11):2022
2.	Specific Conductance, $\mu\text{S}/\text{cm}@25^\circ\text{C}$	512	-	-	IS3025(Part-14):2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS3025(Part-5&6):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS3025(Part-8):2017
5.	Colour, Hazen Units	2	5	15	IS3025(Part-4):2021
6.	Turbidity, NTU	0.05	1	5	IS3025(Part-10):1984
7.	Total Dissolved Solids@105°C, mg/l	292	500	2000	IS3025(Part-16):1984
8.	Alkalinity as CaCO_3 , mg/l	140	200	600	IS3025(Part-23):1986
9.	Total Hardness as CaCO_3 , mg/l	136	200	600	IS3025(Part-21):2009
10.	Calcium as Ca, mg/l	34	75	200	IS3025(Part-40):1991
11.	Magnesium as Mg, mg/l	13	30	100	IS3025(Part-46):1994
12.	Chloride as Cl, mg/l	46	250	1000	IS3025(Part-32):1988
13.	Sulphate as SO_4 , mg/l	115	200	400	IS3025(Part-24):2022
14.	Fluoride as F, mg/l	0.25	1	1.5	APHA23 rd Edition
15.	Nitrate as NO_3 , mg/l	0.0	45	No relaxation	APHA23 rd Edition
16.	Iron as Fe, mg/l	0.035	1	No relaxation	IS3025(Part-53):2003

Remarks: The given sample Conforms to the all parameters are within Acceptable Limit of IS 10500:2012 RA:2018 Drinking Water Specification for The above tested parameter only.

Analysed by : Kavya C E
Senior Analyst/Junior Analyst

Authorized Signatory:
Technical Manager cum senior analyst/Junior analyst

(Signature)
 ಜಿಲ್ಲಾ ಪಂಚಾಯತಿಯ
 ಗ್ರಾಮೀಣ ನೀರು ಸರಬರಾಜು ಮತ್ತು
 ಸ್ವಚ್ಛತೆ ವಿಭಾಗ, ಚಿಕ್ಕಮಗಳೂರು.

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

(Signature)
Principal
 Minority Morarji Desai
 Residential School
 Tegur, Chikmagalur

(Signature)
DISTRICT OFFICER
 Minorities Welfare Dept
 Chikmagalur.