


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 01/23-24

Dated: 17-05-23

It is certified that an inspection team headed by Grama panchayat(Name of Officers with designation) from P.D.O.(Name of Department/ Office) inspected the R. D. P. R(Name & Address of the school) on 17/05/23 (date of inspection) and found that the

Minority Morari Desai Residential School, Medehalli (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of one yearSignature with Seal: 

Name

Panchayath Development Officer

Designation

Grama Panchayat Medehalli,

Chitradurga Dist.

Name & Address of the Office / Department :


To

Minority MorariDesai Residential School, Medehalli.

(Name & Address of the Institution)

Chitradurga

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.


DISTRICT OFFICER
Minority Welfare Department
Chitradurga


Principal
Minority Morari, Desai Residential
School, Medehalli.
Dist Chitradurga-577502



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK

Chitradurga District Water Quality Testing Laboratory
Zilla Panchayath Premesis, Stadium Road, Chitradurga - 577501

Name : Morarji Desai Residential
School

Date : 05-05-2023

Source Type : WPP

Location : Medhehalli, Chitradurga
(T) (D)

Sr. No.	Parameters	Unit	Acceptable limit as per BIS 10500	Permissible limit as per BIS 10500	Results
1	pH*	NA	6.5-8.5	No Relaxation	7.82
2	Turbidity*	NTU	1	5	0.1
3	Conductivity*	micromhos per centimeter	NA	NA	123
4	TDS*	mg/l	500	2000	53.4
5	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	26.5
6	Chloride (as Cl)*	mg/l	250	1000	13.2
7	Total Hardness (As CaCO ₃)*	mg/l	200	600	31
8	Sulphate (as SO ₄)*	mg/l	200	400	10
9	Fluoride (as F)*	mg/l	1	1.5	0.1
10	Nitrate (as NO ₃)*	mg/l	45	No Relaxation	08
11	Iron (As Fe)*	mg/l	1	No Relaxation	0.1

All the above parameters are within the acceptable limits.


DISTRICT OFFICER
Minority Welfare Department
Chitradurga


Principal
Morarji Desai Residential
School, Medhehalli,
Dist Chitradurga-577502


(Senior Analyst)